

10

10

## GREATER WARANGAL MUNICIPAL CORPORATION

From  
Sarfaraz Ahmad, I.A.S.,  
Commissioner,  
Greater Warangal Municipal Corporation,  
Warangal.

To  
The Secretary  
Higher Education,  
Hyderabad

B-I

RC. No. HO/DFO/E-5522/GWMC/COLLEGE/2015, Dt: <sup>3-1-2016</sup> ~~12-2015~~

**Sub;**-Greater Warangal Municipal Corporation – Fire Prevention Wing – Issuance of Renewal of Fire No Objection Certificate for occupancy to the existing non- MSB of M/s Kakatiya Institute of Technology & Science (Block-I) Bheemaram, Hasanparthy, Warangal – Reg.

- Ref:-**
1. Application of the Principal of M/s Kakatiya Institute of Technology & Science, Bheemaram, Hasanparthy, Warangal, Dt:30-03-2015.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. G.O. Ms. No. 71/Home (Prisons. A) Department; Dt: 01-04-2010.
  4. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal vide RC. No. HO/DFO/E-5522/GWMC/COLLEGE/2015, Dt:28-12-2015.

\*\*\*

Under the powers delegated Vide ref 4<sup>th</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science (Block-I), Bheemaram, Hasanparthy, Warangal on 28-12-2015.

2. The Management has constructed the Non Multi storied existing College Building with G+1<sup>st</sup> Floor with a height of 06.00 mtrs, for Educational occupancy (B2) and submitted application for issuance of Renewal of "Fire No Objection Certificate" for the above building.

3. Particulars of the Building

- |   |   |
|---|---|
| a) Address of the Building              | ;M/s Kakatiya Institute of Technology & Science |
|   | Bheemaram                                       |
|   | Hasanparthy, Warangal.                          |
| b) Total Built Up Area/Ht. of Buildings | ; 4,083.28 Sq.mtrs/06.00 mtrs                   |
| c) No. of Blocks / Floor                | : 1 Blocks – G+1 <sup>st</sup> Floor            |
| d) Type of occupancy                    | : Educational Building (B2)                     |

(Contd...2<sup>nd</sup> Page)

7. Additional / Alteration, if any, in the building may be verified by building authority.

8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 67077, Dt:04-12-2015 for Rs. 10,000/- at SBH, Treasury Branch, Hanamkonda.

This Renewal of **Fire No Objection Certificate** is valid from 26-12-2015 to 25-12-2016 and it is the responsibility of the builder / occupier to apply for renewal of Fire NOC, one Month before expiry of this **Fire NOC**.

Commissioner,  
GWMC - Warangal.

**Copy to:**

1. The Principal of M/s Kakatiya Institute of Technology & Science  
Bheemaram, Hasanparthy, Warangal.
2. Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation, Warangal

Signature valid

Digitally signed by GURRALA  
MURALI MANOHAR REDDY  
Date: 2016.01.04 15:50:01 IST

## GREATER WARANGAL MUNICIPAL CORPORATION

3  
B-II

From Sarfaraz Ahmad, I.A.S.,  
Commissioner,  
Greater Warangal Municipal Corporation,  
Warangal.

To  
The Secretary  
Higher Education,  
Hyderabad

RC. No.HO/DFO/E-5523/GWMC/COLLEGE/2015, Dt: 3-1-2016 - 12-2015

**Sub:-** Greater Warangal Municipal Corporation – Fire Prevention Wing – Issuance of Renewal of Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Kakatiya Institute of Technology & Science (Block-II) Bheemaram, Hasanparthy, Warangal - Reg.

- Ref:-**
1. Application of the Principal of M/s Kakatiya Institute of Technology & Science, Bheemaram, Hasanparthy, Warangal, Dt:16-12-2015.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. G.O. Ms. No. 71/Home (Prisons. A) Department, Dt: 01-04-2010.
  4. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal Vide RC. No. HO/DFO/E-5523/GWMC/COLLEGE/2015, Dt:28-12-2015.

\*\*\*

Under the powers delegated Vide ref. 4<sup>th</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science (Block-II) Library, CSE & IT Engg Building Bheemaram, Hasanparthy, Warangal on 02-04-2015.

2. The Management has constructed the Non Multi storied existing College Building with G+1<sup>st</sup> Floor with a height of 06.00 mtrs, for Educational occupancy (B2) and submitted application for issuance of Renewal of "Fire No Objection Certificate" for the above building.

3. Particulars of the Building

- a) Address of the Building ; M/s Kakatiya Institute of Technology &  
Science, Bheemaram  
Bheemaram  
Hasanparthy, Warangal
- b) Total Built Up Area/Ht. of Buildings ; 2547.22 Sq.mtrs/06.00 mtrs
- c) No. of Blocks / Floor ; 1 Blocks – G+1<sup>st</sup> Floor
- d) Type of occupancy ; Educational Building (B2)
- e) Floor wise details ; Given Below

(Contd...2<sup>nd</sup> Page)

- 7. Additional / Alteration, if any, in the building may be verified by building authority.
- 8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 67079, Dt:04-12-2015 for Rs. 10,000/- at SBH, Treasury Branch, Hanamkonda.

This Renewal of **Fire No Objection Certificate is** valid for one year from 26-12-2015 to 25-12-2016 and it is the responsibility of the builder / occupier to apply for renewal of Fire NOC, one Month before expiry of this **Fire NOC**.

**Commissioner,  
GWMC - Warangal.**

**Copy to:**

The Principal of M/s Kakatiya Institute of Technology & Science (BLOCK-II) Bheemaram, Hasanparthy, Warangal.

Copy to Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

*Greddy*  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation, Warangal

**Signature valid**

Digitally signed by SANFARAZ AHMAD  
Date: 2015.12.31 14:49:48 IST

5

B-III

**GREATER WARANGAL MUNICIPAL CORPORATION**

From  
Sarfaraz Ahmad, I.A.S.,  
Commissioner,  
Greater Warangal Municipal Corporation,  
Warangal.

To  
The Secretary  
Higher Education,  
Hyderabad

RC. No. HO/DFO/E-5524/GWMC/COLLEGE/2015, Dt: 3-1-2016  
~~12-2015~~

**Sub:-** Warangal Municipal Corporation – Fire Prevention Wing – Issuance of Renewal of Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Kakatiya Institute of Technology & Science (Block-III) Bheemaram, Hasanparthy, Warangal - Reg.

- Ref:-**
1. Application of the Principal of M/s Kakatiya Institute of Technology & Science, Bheemaram, Hasanparthy, Warangal, Dt: 16-12-2015.
  2. Rc. No. 5041/B2/97, Dt: 12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. G.O. Ms. No. 71/Home (Prisons. A) Department, Dt: 01-04-2010.
  4. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal vide RC.No. HO/DFO/E-5524/GWMC/COLLEGE/2015, Dt: 28-12-2015.

\*\*\*

Vide ref. 3<sup>rd</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science (Block-III) Mech. Engg, ECE Engg Building, Bheemaram, Hasanparthy, Warangal on 28-12-2015.

2. The Management has constructed the Non Multi storied existing College Building with G+1<sup>st</sup> Floor with a height of 06.00 mtrs, for Educational occupancy (B2) and submitted application for issuance of Renewal of **"Fire No Objection Certificate"** for the above building.
3. Particulars of the Building
  - a) Address of the Building : M/s Kakatiya Institute of Technology & Science  
Bheemaram  
Hasanparthy, Warangal
  - b) Total Built Up Area/Ht. of Buildings : 4648.06 Sq.mtrs/06.00 mtrs
  - c) No. of Blocks / Floor : 1 Blocks – G+1<sup>st</sup> Floor
  - d) Type of occupancy : Educational Building (B2)
  - e) Floor wise details : Given Below

(Contd...2<sup>nd</sup> Page)

7. Additional / Alteration, if any, in the building may be verified by building authority.

8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 67081, Dt:04-12-2015 for Rs. 10,000/- at SBH, Treasury Branch, Hanamkonda.


This **Fire No Objection Certificate** is valid for one year from 26-12-2015 to 25-12-2016 and it is the responsibility of the builder / occupier to apply for renewal of Fire NOC, one Month before expiry of this **Fire NOC**.

**Commissioner,  
GWMC - Warangal.**

**Copy to:**

The Principal of M/s Kakatiya Institute of Technology & Science (BLOCK-II) Bheemaram, Hasanparthy, Warangal.

Copy to Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation, Warangal

**Signature valid**

Digitally signed by SAIFARAZ AHMAD  
Date: 2016.01.03 13:34:31 IST

7  
B-IV

## GREATER WARANGAL MUNICIPAL CORPORATION

From  
Sarfaraz Ahmad, I.A.S.,  
Commissioner,  
Greater Warangal Municipal Corporation,  
Warangal.

To  
The Secretary  
Higher Education,  
Hyderabad

RC. No. HO/DFO/E-5521/GWMC/COLLEGE/2015, Dt: 3-1-2016, - 12-2015

**Sub:-** Greater Warangal Municipal Corporation – Fire Prevention Wing – Issuance of Renewal of Fire No Objection Certificate for occupancy to the existing non-MSB of Kakatiya Institute of Technology & Science (Block-IV) Bheemaram, Hasanparthy, Warangal - Reg.

- Ref:-**
1. Application of the Principal of M/s Kakatiya Institute of Technology & Science, Bheemaram, Hasanparthy, Warangal, Dt:16-12-2015.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad
  3. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal vide RC.No. HO/DFO/E-5521/GWMC/COLLEGE/2015, Dt:28-12-2015.

\*\*\*

Vide ref. 1<sup>st</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science (Block-IV), Academic Administrative Building, Bheemaram, Hasanparthy, Warangal on 28-12-2015.

2. The Management has constructed the Non Multi storied existing College Building with Cellar+ G+2 upper Floors with a height of 10.00 mtrs, for Educational occupancy (B2) and submitted application for issuance of Renewal of “**Fire No Objection Certificate**” for the above building.

3. Particulars of the Building

- a) Address of the Building : M/s Kakatiya Institute of Technology & Science  
Bheemaram  
Hasanparthy, Warangal
- b) Total Built Up Area/Ht. of Buildings ; 8415.16 Sq.mtrs/06.00 mtrs
- c) No. of Blocks / Floor : 1 Blocks – G+1<sup>st</sup> Floor
- d) Type of occupancy : Educational Building (B2)

(Contd...2<sup>nd</sup>Page)

3. Fresh NOC would be required for any change in occupancy or addition / alterations in the building structure as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
5. Any Loss of life or property due to Non- functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. Additional / Alteration, if any, in the building may be verified by building authority.
8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 67082, Dt:04-12-2015 for Rs. 10,000/- at SBH, Treasury Branch, Hanamkonda.

This Renewal of **Fire No Objection Certificate** is valid for one year from 26-12-2015 to 25-12-2016, and it is the responsibility of the builder / occupier to apply for renewal of Fire NOC, one Month before expiry of this **Fire NOC**.

**Commissioner,  
GWMC - Warangal.**

**Copy to:**

The Principal of M/s Kakatiya Institute of Technology & Science (BLOCK-II) Bheemaram, Hasanparthy, Warangal.

Copy to Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

*[Handwritten Signature]*  
**District Fire Officer**  
 Fire Prevention Wing  
 Municipal Corporation, Warangal

**Signature valid**

Digitally signed by SARFARAZ AHMAD  
 Date: 2016.01.03 15:38:39 IST



PROCEEDINGS OF THE COMMISSIONER, GREATER WARANGAL MUNICIPAL CORPORATION

Present: Sri Sarfaraz Ahmad, I.A.S.,

Rc.No. HO/DFO/E-22179/GWMC/COLG/2016,

Dt: 4-07-2016.

**Sub:-** Warangal Municipal Corporation – Fire Prevention Wing – Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Kakatiya Institute of Technology & Science C. S.E & I.T Building (Block-V), Bheemaram, Hasanparthy, Warangal – Order issued-Reg.

- Ref:-**
1. Application of the Project Officer of M/s Kakatiya Institute of Technology & Science ,Bheemaram,Hasanparthy, Warangal, Dt:25-05-2016.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal vide RC.No.HO/DFO/E-22179/GWMC/COLLEGE/2016, Dt:30-06-2016.

\*\*\*

**ORDER:**

Under the powers delegated vide ref. 2<sup>nd</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science C.S.E & I.T Building (Block-V), Bheemaram, Hasanparthy, Warangal on 30-06-2016.

2. The Management has constructed the Non Multi storied existing College Building with G+2 Upper Floor with a height of 11.30 mtrs, for Educational occupancy (B2) and submitted application for issuance of “**Fire No Objection Certificate**” for the above building.
3. Particulars of the Building
 

a) Address of the Building	; M/s Kakatiya Institute of Technology & Science C. S.E & I.T uilding (Block-V), Bheemaram, Hasanparthy, Warangal
b) Total Built Up Area/Ht. of Buildings	; 2597.58 Sq.mtrs/11.30 mtrs
c) No. of Blocks / Floor	: 1 Block – G+2 Upper Floors
d) Type of occupancy	: Educational Building (B2)
e) Floor wise details	: Given Below

(Contd...2<sup>nd</sup> Page)

- 7. Additional / Alteration, if any, in the building may be verified by building authority.
- 8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 66517, Dt:25-05-2016 for Rs. 25,970/- at SBH, Treasury Branch, Hanamkonda..

**Commissioner,  
GWMC - Warangal.**

To,

The Principal of M/s Kakatiya Institute of Technology & Science C.S.E & I.T Building (Block-V), Bheemaram, Hasanparthy, Warangal

Copy to the Secretary, Higher Education, Hyderabad for information

Copy to the Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation... Warangal

Signature valid

Digitally signed by GURRALA MURALI MANOHAR REDDY  
Date: 2016.07.04 13:40:00 IST  
Reason: Approved

PROCEEDINGS OF THE COMMISSIONER, GREATER WARANGAL MUNICIPAL CORPORATION

Present: Sri Sarfaraz Ahmad, I.A.S.,

Rc.No. HO/DFO/E-22182/GWMC/RES/2016,

Dt: 4-07-2016.

**Sub:-** Warangal Municipal Corporation – Fire Prevention Wing – Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Kakatiya Institute of Technology & Science Girls hostel Building at Sy No.136, Bheemaram, Hasanparthy, Warangal – Order issued-Reg.

- Ref:-**
1. Application of the Project Officer of M/s Kakatiya Institute of Technology & Science ,Bheemaram,Hasanparthy, Warangal, Dt:25-05-2016.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal videRC.No.HO/DFO/E-22182/GWMC/COLLEGE/2016, Dt:30-06-2016.

\*\*\*

**ORDER:**

Under the powers delegated vide ref. 2<sup>nd</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science Girls hostel Building at Sy No.136, Bheemaram, Hasanparthy, Warangal on 30-06-2016.

2. The Management has constructed the Non Multi storied existing College Building with G+2 Upper Floor with a height of 10.80 mtrs, for Residential Building (A3) and submitted application for issuance of “**Fire No Objection Certificate**” for the above building.

3. Particulars of the Building

- |   |   |   |
|---|---|---|
| a) Address of the Building              | ; | M/s Kakatiya Institute of Technology & Science Girls hostel<br>Sy No.136, Bheemaram,<br>Hasanparthy, Warangal |
| b) Total Built Up Area/Ht. of Buildings | ; | 6769.65 Sq.mtrs/10.80 mtrs  |
| c) No. of Blocks / Floor                | ; | 1 Block – G+2 Upper Floors  |
| d) Type of occupancy                    | ; | Residential Building (A3)   |
| e) Floor wise details                   | ; | Given Below   |

(Contd...2<sup>nd</sup> Page)

- 7. Additional / Alteration, if any, in the building may be verified by building authority.
- 8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 66512, Dt:25-05-2016 for Rs. 67,700/- at SBH, Treasury Branch, Hanamkonda.

**Commissioner,  
GWMC - Warangal.**

To,  
The Project Officer of M/s Kakatiya Institute of Technology & Science, Girls Hostel Building, Bheemaram, Hasanparthy, Warangal  
Copy to the Secretary, Higher Education, Hyderabad for information  
Copy to the Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

*[Handwritten Signature]*  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation, Warangal

**Signature valid**

Digitally signed by GURRALA MURALI MANOHAR REDDY  
Date: 2016.07.04 19:36:12 IST  
Reason: Approved

PROCEEDINGS OF THE COMMISSIONER, GREATER WARANGAL MUNICIPAL CORPORATION

Present: Sri Sarfaraz Ahmad, I.A.S.,

Rc.No. HO/DFO/E-22180/GWMC/RES/2016,

Dt: 4-07-2016.

**Sub:-** Warangal Municipal Corporation – Fire Prevention Wing – Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Kakatiya Institute of Technology & Science Boys hostel-I Building at Sy No.713, Mucherla, Hasanparthy, Warangal – Order issued-Reg.

- Ref:-**
1. Application of the Project Officer of M/s Kakatiya Institute of Technology & Science ,Bheemaram,Hasanparthy, Warangal, Dt:25-05-2016.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal vide RC.No.HO/DFO/E-22180/GWMC/COLLEGE/2016, Dt:30-06-2016.

\*\*\*

**ORDER:**

Under the powers delegated vide ref. 2<sup>nd</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science Boys hostel-I Building at Sy No.713, Mucherla, Hasanparthy, Warangal on 30-06-2016.

2. The Management has constructed the Non Multi storied existing College Building with G+2 Upper Floor with a height of 10.60 mtrs, for Residential Building (A3) and submitted application for issuance of “**Fire No Objection Certificate**” for the above building.

3. Particulars of the Building

- |   |   |
|---|---|
| a) Address of the Building              | : M/s Kakatiya Institute of Technology & Science Boys hostel-I Building<br>Sy No.713, Mucherla, Hasanparthy, Warangal |
| b) Total Built Up Area/Ht. of Buildings | : 5066.16 Sq.mtrs/10.60 mtrs  |
| c) No. of Blocks / Floor                | : 1 Block – G+2 Upper Floors  |
| d) Type of occupancy                    | : Residential Building (A3)   |
| e) Floor wise details                   | : Given Below   |

(Contd...2<sup>nd</sup> Page)

- 7. Additional / Alteration, if any, in the building may be verified by building authority.
- 8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 66515, Dt:25-05-2016 for Rs. 50,660/- at SBH, Treasury Branch, Hanamkonda.

**Commissioner,  
GWMC - Warangal.**

To,  
The Project Officer of M/s Kakatiya Institute of Technology & Science, Boys hostel-I Building, Mucherla, Hasanparthy, Warangal  
Copy to the Secretary, Higher Education, Hyderabad for information  
Copy to the Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

*[Handwritten Signature]*  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation, Warangal

**Signature valid**

Digitally signed by GUNRALA MURALI MANOHAR REDDY  
Date: 2016.07.04 10:38:39 IST

## PROCEEDINGS OF THE COMMISSIONER, GREATER WARANGAL MUNICIPAL CORPORATION

Present: Sri Sarfaraz Ahmad, I.A.S.,

Rc.No. HO/DFO/E-22183/GWMC/RES/2016,

Dt: 4-07-2016.

**Sub:-** Warangal Municipal Corporation – Fire Prevention Wing – Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Kakatiya Institute of Technology & Science Boys hostel-II Building at Sy No.713, Mucherla, Hasanparthy, Warangal – Order issued-Reg.

- Ref:-**
1. Application of the Project Officer of M/s Kakatiya Institute of Technology & Science ,Bheemaram,Hasanparthy, Warangal, Dt:25-05-2016.
  2. Rc. No. 5041/B2/97, Dt:12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.
  3. Inspection report of Officers of Fire Prevention Wing, GWMC, Warangal vide RC.No.HO/DFO/E-22183/GWMC/COLLEGE/2016, Dt:30-06-2016.

\*\*\*

**ORDER:**

Under the powers delegated vide ref. 2<sup>nd</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s Kakatiya Institute of Technology & Science Boys hostel-II Building at Sy No:713, Mucherla, Hasanparthy, Warangal on 30-06-2016.

2. The Management has constructed the Non Multi storied existing College Building with G+2 Upper Floor with a height of 10.60 mtrs, for Residential occupancy (A3) and submitted application for issuance of “**Fire No Objection Certificate**” for the above building.
3. Particulars of the Building
  - a) Address of the Building ; M/s Kakatiya Institute of Technology & Science Boys hostel-I Building Sy No.713, Mucherla, Hasanparthy, Warangal
  - b) Total Built Up Area/Ht. of Buildings ; 2511.72 Sq.mtrs/10.60 mtrs
  - c) No. of Blocks / Floor ; 1 Block – G+2 Upper Floors
  - d) Type of occupancy ; Residential Building (A3)
  - e) Floor wise details ; Given Below

(Contd...2<sup>nd</sup> Page)

- 7. Additional / Alteration, if any, in the building may be verified by building authority.
- 8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Management has remitted Fire precautionary fee through Vide Challan No. 66509, Dt:25-05-2016 for Rs. 25,120/- at SBH, Treasury Branch, Hanamkonda.


**Commissioner,  
GWMC - Warangal.**

To,

The Project Officer of M/s Kakatiya Institute of Technology & Science, Boys hostel-II Building, Mucherla, Hasanparthy, Warangal

Copy to the Secretary, Higher Education, Hyderabad for information

Copy to the Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.

  
**District Fire Officer**  
Fire Prevention Wing  
Municipal Corporation, Warangal

Signature valid

Digitally signed by GURRALA RALI MANOHAR REDDY  
Date: 2016.07.04 10:37:30 IST  
Reason: Approved